

# ELEKTROTECHNICKÝ ZKUŠEBNÍ ÚSTAV



ELECTROTECHNICAL TESTING INSTITUTE - CZECH REPUBLIC  
ELEKTROTECHNISCHE PRÜFANSTALT - TSCHHECHISCHE REPUBLIK  
INSTITUT ELECTROTECHNIQUE D'ESSAIS - RÉPUBLIQUE TCHÉQUE  
ЭЛЕКТРОТЕХНИЧЕСКИЙ ИСПЫТАТЕЛЬНЫЙ ИНСТИТУТ - ЧЕШСКАЯ РЕСПУБЛИКА

Pod lisem 129/2, Troja, 182 00 Praha 8

## CERTIFICATE

No.: 1260072

**Product:** Electrical insulating matting

**Type:** DEK0-S7-26

**Rating:** class 0

**Ordering firm:** BOGUMA, s. r. o.  
Továrenská 314, 95618 Bošany, Slovakia

**Manufacturer:** BOGUMA, s. r. o.  
Továrenská 314, 95618 Bošany, Slovakia

**Trade mark:**

The test results are stated in the test-report No.: 260264-01/01 of: 18.02.2026

A sample of the product was found to be in conformity with:

ČSN EN 61111:2010 (idt. IEC 61111:2009)

cl. 5.2.2, 5.2.3, 5.2.5, 5.3, 5.5.2, 5.5.3, 5.6.2.2, 5.6.2.3, 5.6.4.2, 5.6.4.3, 5.7, 5.8.1, 5.8.2, 5.9, 5.10

**Other data:**

The validity of the certificate is limited to: 24.02.2029

25.02.2026

Prague

Mgr. Miroslav Sedláček  
Head of Certification Body



260264-01